



INTERIOR PLAN
NTS

NOTES:

1. PRESSURE REDUCING STATION SHALL BE MANUFACTURED BY ENGINEERED FLUID, INC. (E.F.I.), CENTRALIA, ILLINOIS.
2. PRESSURE REDUCING VALVES SHALL BE CLA-VAL MODEL 90G-01ABCS WITH STAINLESS STEEL TRIM, AND X-101 VALVE POSITION INDICATORS.
3. ALL PIPING SHALL BE SCHEDULE 40 STEEL PIPE WITH FUSION BONDED EPOXY ON INTERIOR.
4. ALL FITTINGS SHALL BE INTEGRAL TO THE STATION.
5. PROVIDE TWO COATS TNEPEC SERIES 66 HI-BUILD EPOXOLINE ON ALL STEEL SURFACES, MIN. 4 MILS DFT PER COAT.
6. PROVIDE WESTERN WATER WITH SHOP SUBMITALS FOR APPROVAL PRIOR TO FABRICATION.
7. HYDRAULIC CONDITIONS
 INLET PRESSURE: _____
 SMALL PRV SETTING: _____
 LARGE PRV SETTING: _____